

Application of Non-superconducting Fault Current Limiter to Improve Transient Stability

Mehrdad Tarafdar Hagh¹, *Member, IEEE*, Seyed Behzad Naderi² and Mehdi Jafari², *Student Member, IEEE*

¹Mechatronic Center of Excellence, University of Tabriz, Tabriz, IRAN

²Faculty of Electric & Electronic Engineering, University of Tabriz, Tabriz, IRAN

Emails: tarafdar@tabrizu.ac.ir, s.b.naderi87@ms.tabrizu.ac.ir, m.jafari87@ms.tabrizu.ac.ir

Abstract —In this paper, enhancement of transient stability of Single Machine Infinite Bus (SMIB) system with a double circuit transmission line using a Non-superconducting Fault Current Limiter (NSFCL) is proposed. Stability analysis for such system is discussed in detail. It is shown that, the stability depends on the resistance of NSFCL in fault condition. To effective improvement of stability, the optimum value of NSFCL resistance is calculated. Simulation results by PSCAD/EMTDC software are presented to confirm the analytic analysis accuracy.

Keywords—fault current limiter; transient stability; non-superconducting coil; optimum resistor

I. INTRODUCTION

Power systems have become more expanded due to the increasing electric power demand. To increase the reliability for power supply, the electric power systems are interconnected each other to give and take the electric power [1]. Therefore, the available fault currents level may exceed the maximum short-circuit ratings of the switchgear. Traditionally, to moderate the cost of switchgear and bus replacements, the most common ways to limit high-level fault currents are: splitting the power grid and introducing higher voltage connections, using current-limiting fuses or series reactors or high-impedance transformers, and using complex strategies like sequential network tripping [2, 3].

A better idea to limit the fault currents and prevent high costs is usage of FCLs. FCLs in electric power systems are also utilized to variety of performances such as the power system transient stability enhancement, power quality improvement, reliability improvement, increasing transfer capacity of system equipment, and inrush current limitation in transformers [3]-[6].

Some studies are done on system applications of FCLs recently. For transient stability studies, they are focused on superconductor type FCLs generally, and on Resistive type SFCLs (RSFCL) specially. Because the RSFCLs can consume the accelerating power of generators in fault condition and therefore, enhance the stability of the power system [6]-[11].

To the best knowledge of authors, [10] and [11] are discussed on the optimum value of resistor of superconductor. They try to make a RSFCL that has optimal resistor value in fault condition. But there are two problems. Firstly, because of

high technology and cost of superconductors, these devices are not commercially available. Especially in third world countries, design, manufacture and operation costs providing is impossible approximately. Secondly, resistance that RSFCL shows in fault condition is not constant during the fault due to its quenching characteristics [11]. So, it is not possible to equate RSFCL's resistance to the calculated optimal value.

The optimum value for resistor of FCL that is installed at the beginning of the parallel lines is calculated infinite at [10]. In this state, faulted line will be isolated. But we will show that the optimal value for FCL resistor should have finite value and rotor speed swings in this case will be reduced to lower values.

In this paper, a structure of NSFCL is introduced. Transient stability analysis for SMIB system with a double circuit transmission line is studied and the optimum value for resistor of NSFCL is computed. The optimal value is finite and synchronous generator will have better stability than the optimal value computed at [10]. Finally, EMTDC/PSCAD software is used to show the effectiveness of optimum resistor value for enhancement of transient stability.

II. POWER CIRCUIT TOPOLOGY OF NSFCL AND ITS OPERATION

The three phase topology of proposed NSFCL is shown in Fig. 1. This circuit is composed of following main parts: Three sets of single phase transformers, utilized as power isolation transformer, are connected to a three phase diode rectifier bridge; A non-superconductor (copper coil) magnet that is modeled by a resistor (r_d) and an inductor (L_{dc}); A parallel connection of a resistor (R) and a semiconductor switch (IGBT) that are connected in series with the dc reactor; A dc voltage source (V_{dc}) used to compensate the voltage drop that take place in both dc reactor resistance and semiconductor devices. So, it equals to [12]:

$$V_{dc} = 2V_{DF} + V_{IGBT} + r_d I_{dc} \quad (1)$$

Where V_{IGBT} stands for the voltage drop across IGBT and the forward voltage drop across rectifier diodes is defined as V_{DF} .




Figure 1. Power circuit topology of proposed NSFCL

In normal operation of power system, IGBT switch is ON. So, the resistor is bypassed. By compensating the voltage drop on diodes, IGBT and r_d , total voltage drop on FCL becomes almost zero. Therefore, FCL does not affect normal operation of power system.

As fault occurs, dc current starts to increase. When control circuit detects fault conditions, IGBT turns off. So, R enters to the current path and limits the fault current. By removal of fault, IGBT turns on again and power system returns to the normal state.

It is important to note that, if the value of the resistance that NSFCL shows in fault condition at ac side of rectifier bridge, $R_{FCL,ac}$, be optimum from the stability point of view, it will lead to the best improvement of power system transient stability. On the other hand, the value of $R_{FCL,ac}$ is proportional to the value of R . So, it is possible to achieve to the best enhancement of stability by selecting a proper value for R . Note that the value of L_{dc} does not affect the impedance of NSFCL.

III. TRANSIENT STABILITY ANALYSIS USING NSFCL

Fig. 2 shows single line diagram of power system with NSFCL at the beginning of one of the parallel lines. We assume that reactance of parallel lines (X_L) are equal. At pre-fault condition, transfer power can be expressed by:

$$P = (EV/X) \sin \delta_0 \quad (2)$$

where:

E : RMS line to line synchronous generator voltage

V : RMS line to line infinite bus voltage

X : Total reactance ($X_t = X_d + X_t + X_L/2$)

X_d : Unsaturated reactance of generator

X_t : Transformer reactance

X_L : Line reactance

δ_0 : Load angle

When fault occurs at point F, without using NSFCL, because of reducing transfer power, synchronous generator will be unstable, probably (depends on fault type and mechanical power of generator (p_m)). Using NSFCL at the beginning of the parallel lines can ensure stability of generator. Fig. 3 shows the equivalent circuit at fault state with NSFCL after applying star to delta transformation in Fig. 2.

To compute output power of generator, firstly, we calculate output current of generator (I_g) in Fig. 3. So we have:

$$I_g = (E \angle \delta / |Z_b| \angle \alpha_2) + ((E \angle \delta - V \angle 0) / |Z_a| \angle \alpha_1) \quad (3)$$

$$\begin{cases} Z_a = b + c + (bc/a) \\ Z_b = a + c + (ac/b) \\ a = Z_F + (jRX_L / (R + j2X_L)) \\ b = -X_L^2 / (R + j2X_L) \\ c = jX' + (jRX_L / (R + j2X_L)) \\ X' = X_d' + X_t \end{cases} \quad (4)$$

Where Z_F and X_d' are fault impedance and unsaturated transient reactance, respectively. In the worst condition that three phase fault occurs, Z_F is equal to zero, approximately.

In fault condition, output power of generator can be expressed by:

$$P_f = \text{real}(I_g^* E \angle \delta) = (E^2 / |Z_a|) \cos \alpha_1 + (E^2 / |Z_b|) \cos \alpha_2 + (EV / |Z_a|) \sin(\delta + \alpha_1 - \pi/2) \quad (5)$$




Figure 2. Single line diagram of power system with NSFCL




Figure 3. Equivalent circuit in fault condition with NSFCL

It is clear that (5) depends on $R_{FCL,ac}$ and it is sum of the consumed power of NSFCL resistance and the transfer power. To achieve the minimum rotor speed swing of synchronous generator after fault, the optimal value of $R_{FCL,ac}$ must be chosen. It is obvious that minimum rotor speed swing results in maximum critical load angle. To obtain the optimal value of $R_{FCL,ac}$, output power of generator in fault condition and pre-fault condition should be equated. In this state, consumed power of $R_{FCL,ac}$ be equated faulted line transfer power before fault. In addition, because of same characteristics of parallel lines, transfer powers of each line are equal. So we have:

$$P_{FL} = (V_{PCC}^2 / R_{FCL,ac}) = (EV / 2X) \sin \delta_0 \quad (6)$$

$$R_{FCL,ac} = (2V_{PCC}^2 X) / (EV \sin \delta_0) \quad (7)$$

Where V_{PCC} and P_{FL} are point of common coupling voltage and faulted line transfer power in fault duration, respectively. In addition, V_{PCC} can be expressed by:

$$V_{PCC} = E \angle \delta - jX I_g \quad (8)$$

where I_g is computed from (3).

Fig. 4 shows the power-angle curves of synchronous generator. For optimal value of $R_{FCL,ac}$, power-angle curve in fault duration is passes work point of generator before fault.

It should be noticed that $R_{FCL,ac}$ is not equal to numerical value of resistor at dc side of diode rectifier bridge ($R_{FCL,dc}$). Therefore, value of $R_{FCL,dc}$ must be calculated according to the optimum $R_{FCL,ac}$ value.

To obtain the relation between $R_{FCL,ac}$ and $R_{FCL,dc}$, ac and dc sides active powers ($P_{FCL,ac}$ and $P_{FCL,dc}$, respectively) must be considered equal. So:




Figure 4. Power-angle curves of synchronous generator

$$P_{FCL,ac} = P_{FCL,dc} \quad (9)$$

$$3 \frac{\left(\frac{V_m}{\sqrt{2}} \right)^2}{R_{FCL,ac}} = \frac{\left(\frac{6}{\pi} \sin\left(\frac{\pi}{3}\right) V_m \right)^2}{R_{FCL,dc}} \quad (10)$$

Where, V_m is the peak of isolation transformer secondary voltage.

As a result:

$$R_{FCL,dc} = \left(\frac{18}{\pi^2} \right) R_{FCL,ac} \quad (11)$$

IV. SIMULATION RESULTS

Simulations are performed on a power system such as Fig. 2. Parameters of simulation are as Table I.

Fault occurs at 20 (sec) and lasts 0.16 (sec) (8 cycles of power system frequency).

Fig. 5 shows the phase A voltage of generator terminal without NSFCL in the system. It is observed that voltage distortions take place and system becomes unstable. But by installing the NSFCL at the beginning of faulted line, voltage of generator is restored and instability is prevented. Fig. 6 shows the phase A voltage of generator terminal with NSFCL and proves this fact.

Generator current with and without NSFCL is shown in Fig. 7 and 8. Fig. 7 shows that without using NSFCL, fault current is not limited and therefore, generator can not hold its stability. By using NSFCL, as shown in Fig. 8, the fault current is limited properly and generator became stable.

Fig. 9 shows the consumed power of NSFCL during the fault for three values of R as follows: 3 (p.u.), 6.85 (p.u.) (the optimum value) and 12 (p.u.). Considering Fig. 9, it is clear that the consumed power by NSFCL during the fault for optimum value of R is closer to the pre-fault value of the

TABLE I. SIMULATION PARAMETERS

| | | |
|--------------------------------|---|---|
| Power system parameters | Generator | 4 poles, 200V, L-L RMS, 50Hz, $S_b = 18.25 \text{ kVA}$, $P_m = 0.6 \text{ p.u.}$ $X_d = 1.227 \text{ p.u.}$, $X'_d = 0.394 \text{ p.u.}$ |
| | Transformer data | 200/200 V, 20kVA, $X_t = 0.00145 \text{ H}$ |
| | Infinite bus | 210V, L-L RMS |
| | Transmission lines | $X_L = 0.0064 \text{ H}$ |
| FCL data | dc side parameters | $R_{opt} = 15 \Omega$, $r_d = 0.3 \Omega$, $L_d = 0.15 \text{ H}$ $V_{DF} = V_{SW} = 1 \text{ V}$ |
| | Isolation transformer parameters | 50Hz, 5kVA, $a = 1$ |

transmitted power from the faulted line. So, it leads to decrease the accelerating area and consequently, minimize the oscillations of generator rotor speed. Fig. 10 shows the rotor speed oscillations of generator for different values of R after the fault. It is important to note that the best response is observed for the case that NSFCL had the optimum value of R . In this case, rotor speed oscillation is lower than the cases that NSFCL has other values of R .




Figure 5. Phase A voltage of generator terminal without NSFCL




Figure 6. Phase A voltage of generator terminal with NSFCL




Figure 7. Generator current without NSFCL




Figure 8. Generator current with NSFCL




Figure 9. Consumed power of NSFCL during the fault for three values of R




Figure 10. Rotor speed oscillations of generator

V. CONCLUSION

In this paper transient stability improvement of power system with double circuit transmission line using NSFCL is presented. Proposed structure can enter an optimum value of resistor to the utility without needing to isolate faulted line. Optimum resistor leads to proper enhancement of transient stability. Analytical analyses are performed for pre-fault and fault conditions. Simulation results by EMTDC/PSCAD are involved for different values of resistor to validate the effectiveness of optimum resistor value. In general, proposed structure with low cost and available technology has good capability to improve the transient stability.

REFERENCES

- [1] Y. Shirai, K. Furushiba, Y. Shouno, M. Shiotsu, and T. Nitta, "Improvement of Power System Stability by Use of Superconducting Fault Current Limiter With ZnO Device and Resistor in Parallel," *IEEE Trans. Appl. Supercond.*, vol. 18, no. 2, pp. 680-683, June 2008.
- [2] Lin Ye, LiangZhen Lin, and Klaus-Peter Juengst, "Application Studies of Superconducting Fault Current Limiters in Electric Power Systems," *IEEE Trans. Appl. Supercond.*, vol. 12, no. 1, pp. 900-903, March 2002.
- [3] Mehrdad Tarafdar Hagh, Mehdi Abapour, "Nonsuperconducting Fault Current Limiter With Controlling the Magnitudes of Fault Currents," *IEEE Trans. Power Elc.*, vol. 24, no. 3, pp. 613-619, March 2009.
- [4] M. M. R. Ahmed, G. A. putrus, L. Ran, "Power Quality Improvement Using Solid State Fault Current limiter," *IEEE, Transmission and Distribution Conference, Asia Pacific*, vol. 2, pp. 1059-1064, Oct. 2002.
- [5] M. Tarafdar Hagh and M. Abapour, "DC reactor type transformer inrush current limiter," *IET Electr. Power*, vol. 1, no. 5, pp. 808-814, Appl., 2007.
- [6] M. Tsuda, Y. Wlitani, K. Tsuji, K. Kakihana, "Application of Resistor Based Superconducting Fault Current Limiter to Enhancement of Power System Transient Stability," *IEEE Trans. Appl. Supercond.*, vol. 11, no. 1, pp. 2122-2125, March 2001.

- [7] K. Furushiba, T. Yoshii, Y. Shirai, K. Fushiki, J. Baba and T. Nitta, "Power System Characteristics of the SCFCL in Parallel With a Resistor in Series With a ZnO Device," *IEEE Trans. Appl. Supercond.*, vol. 17, no. 2, pp. 1915-1918, June 2007.
- [8] H. Hooshyar, M. Savaghebi, "RSFCL Optimum Shunt Resistance Determination to Enhance Power System Transient Stability," *Universities Power Engineering Conference, UPEC, 43rd International*, pp. 1-5, September 2008.
- [9] Hiroyuki Hatta, Shinichi Muroya, Tanzo Nitta, Yasuyuki Shirai, and Masaumi Taguchi, "Experimental Study on Limiting Operation of Superconducting Fault Current Limiter in Double Circuit Transmission Line Model System," *IEEE Trans. Appl. Supercond.*, vol. 12, no. 1, pp. 812-815, March 2002.
- [10] Y. Ye, L. Xiao, H. Wang, and Z. Zhang, "Research on resistor type superconducting fault current limiter in power system," in *Proc. IEEE/PES Transmiss. Distrib. Conf. Exhib., Asia Pacific*, 2005.
- [11] Byung Chul Sung, Dong Keun Park, Jung-Wook Park, and Tae Kuk Ko, "Study on a Series Resistive SFCL to Improve Power System Transient Stability: Modeling, Simulation, and Experimental Verification," *IEEE Trans. Ind. Elec.*, vol. 56, no. 7, pp. 2412-2419, July 2009.
- [12] M. Tarafdar Hagh and M. Abapour, "Non-superconducting fault current limiters," *Euro. Trans. Electr. Power*, vol. 19, no. 5, pp. 669-682, 27 Mar. 2008.